

CERTIFICATE OF COMPLIANCE

Certificate Number 20170217-EX26789
Report Reference EX26789-20170216
Issue Date 2017-FEBRUARY-17

Issued to: Global Fire Solution Pte Ltd
No, 16 Penjuru Close
608612 SINGAPORE

**This is to certify that
representative samples of**

FOAM LIQUID CONCENTRATES

Foam liquid concentrates as follows: GLOBALCHEM AFFF
1, GLOBALCHEM AFFF 3, GLOBALCHEM AFFF 6,
GLOBALCHEM AR-AFFF 3/3

Have been investigated by UL in accordance with the
Standard(s) indicated on this Certificate.

Standard(s) for Safety: UL 162, UL Standard for Safety for Foam Equipment and
Liquid Concentrates

Additional Information: See the UL Online Certifications Directory at
www.ul.com/database for additional information

Only those products bearing the UL Certification Mark should be considered as being covered by UL's
Certification and Follow-Up Service.

Look for the UL Certification Mark on the product.



Bruce Mahrenholz, Director North American Certification Program

UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please
contact a local UL Customer Service Representative at <http://ul.com/about/locations/>



Foam Liquid Concentrate

AQUEOUS FILM FORMING FOAM
CONCENTRATE

1%

GLOBALCHEM AFFFI

FOR USE ON HYDROCARBON FIRES AT 1% PROPORTIONING RATIO
SUITABLE FOR USE WITH BOTH FRESH & SEA WATER

Storage Temperature Min 35° F (1.7° C), Max 120° F (49° C)

Caution: DO NOT store under direct sun

BATCH NO.
MFG DATE:
CONTENTS (LTRS.) 20 / 30 / 200

Manufactured in Singapore



LISTED
FOAM LIQUID
CONCENTRATE
EX26789

Global Fire Solution (Singapore) Pte. Ltd.

16 Penjuru Close, Singapore 608612 ☎ (+65) 6897 7086 ✉ vrajan@gms.com.sg

www.gfsglobalchem.com

C171961319

Foam Liquid Concentrate

AQUEOUS FILM FORMING FOAM
CONCENTRATE

3%

GLOBAL CHEM AFFERS

FOR USE ON HYDROCARBON FIRES AT 3% PROPORTIONING RATIO

SUITABLE FOR USE WITH BOTH FRESH & SEA WATER

Storage Temperature Min 35° F (1.7° C), Max 120° F (49° C)

Caution: DO NOT store under direct sun

Global Fire Solution (Singapore) Pte. Ltd.

16 Penjuru Close, Singapore 600612 ☎ (+65) 6897 7006 ✉ vrajani@gms.com.sg

www.gfsglobalchem.com

BATCH NO.

MFG DATE:

CONTENTS (LTRS.)
20 / 30 / 200

Manufactured in Singapore



LISTED
FOAM LIQUID
CONCENTRATE
EX26789

C171961320

Foam Liquid Concentrate

AQUEOUS FILM FORMING FOAM
CONCENTRATE

6%

GLOBALCHEM AFFFB6

FOR USE ON HYDROCARBON FIRES AT 6% PROPORTIONING RATIO

SUITABLE FOR USE WITH BOTH FRESH & SEA WATER

Storage Temperature Min 35° F (1.7° C), Max 120° F (49° C)

Caution: DO NOT store under direct sun

Global Fire Solution (Singapore) Pte. Ltd.

16 Penjuru Close, Singapore 608612 ☎ (+65) 6897 7086 ✉ vrajai@gms.com.sg

www.gfsglobalchem.com

BATCH NO.
MFG DATE:
CONTENTS (LTRS.) 20 / 30 / 200

Manufactured in Singapore



LISTED
FOAM LIQUID
CONCENTRATE
EX26789

C171961321

Foam Liquid Concentrate

ALCOHOL RESISTANT AQUEOUS
FILM FORMING FOAM CONCENTRATE

3/3

GLOBAL CHEM AR-AFFF-3/3

C171961322

FOR USE ON HYDROCARBON FIRES &
POLAR SOLVENTS AT 3% PROPORTIONING RATIO
SUITABLE FOR USE WITH BOTH FRESH & SEA WATER
Storage Temperature Min 35° F (1.7° C), Max 120° F (49° C)

Caution: DO NOT store under direct sun

Global Fire Solution (Singapore) Pte. Ltd.
16 Penjuru Close, Singapore 608612 ☎ (+65) 6897 7086 ✉ vrajai@gms.com.sg
www.gfsglobalchem.com

BATCH NO.
MFG DATE:
CONTENTS (LTRS.) 20 / 30 / 200

Manufactured in Singapore



LISTED
FOAM LIQUID
CONCENTRATE
EX26789

File EX26789
Project 4787742638

February 16, 2017

REPORT

on

Foam Liquid Concentrates

Global Fire Solution Pte Ltd
Singapore

Copyright © 2017 UL LLC

UL LLC authorizes the above named company to reproduce this Report only for purposes as described in the Conclusion, provided it is reproduced in its entirety.

DESCRIPTION

PRODUCT COVERED:

GLOBALCHEM AFFF 1, nominal 1 percent Aqueous Film Forming Foam, +35 F minimum storage and use temperature. Hydrocarbon fuels only.

Foam concentrates for use with the following equipment.

GLOBALCHEM AFFF 1, 1 Percent

PROPORTIONERS - PORTABLE IN-LINE INDUCTORS

ANGUS FIRE LTD, Model UNI225-1/3, 2-1/2 in. size, set at 1, inlet pressure of 145 psi with 100 feet of 2-1/2 in. hose between inductor and ANGUS FIRE LTD, Model F225U nozzle.

NOZZLES

Description	Size In.	Inlet Pressure psi
Angus Fire Ltd, Model F225HU	2-1/2	80

GENERAL:

CONSTRUCTION DETAILS:

The products have been examined and found to comply with the Standard for Foam Equipment and Liquid Concentrates, UL 162 in effect as of the date of this Report.

USE:

The products covered by this Report are for use in accordance with the National Fire Protection Association Standards for Low Expansion Foam, and/or Foam-Water Sprinklers and Foam-Water Spray Systems, NFPA 11 and 16, respectively.

GENERAL CHARACTER:

Foam liquid concentrates are formulated for addition to water to produce solutions capable of forming fire-fighting foams when the solutions are discharged under pressure through foam making devices.

The foam liquid concentrate covered by this Report is of the Alcohol Resistant Aqueous Film Forming Foam type and is for use in 1 percent solutions for use on hydrocarbon type fuels.

This foam liquid concentrate is suitable for use when the foam temperature is between 35°F (1.7°C) and 120°F (49°C).

TEST RECORD NO. 1

SAMPLES:

Samples of the product as indicated below and constructed as described herein, was submitted by the manufacturer for examination and test.

GLOBALCHEM AFFF 1, nominal 1 percent Aqueous Film Forming Foam, +35 F minimum storage and use temperature. Hydrocarbon fuels only.

Foam concentrates for use with the following equipment.

GLOBALCHEM AFFF 1, 1 Percent

PROPORTIONERS - PORTABLE IN-LINE INDUCTORS

ANGUS FIRE LTD, Model UNI225-1/3, 2-1/2 in. size, set at 1, inlet pressure of 145 psi with 100 feet of 2-1/2 in. hose between inductor and ANGUS FIRE LTD, Model F225U nozzle.

NOZZLES

Description	Size In.	Inlet Pressure psi
Angus Fire Ltd, Model F225HU	2-1/2	80

GENERAL:

The following tests were conducted:

Test	Paragraph/Clause
Film Forming	6
Foam Quality	8
Class B Fire Tests - Topside Discharge Devices	10
Induction Rate	12
Minimum Storage Temperature	13
Nonmetallic Container Tests - Accelerated Storage	22.3

The following tests were waived:

Test	Rational for Waived Test+	File Reference	Report Date	Test Record No.
Nonmetallic Container Tests - Immersion test for cracking resistance	1	EX27367	0000-00-00	1
Nonmetallic Container Tests - Air-oven aging test	1	EX27367	0000-00-00	1
Nonmetallic Container Tests - Light and water test	1	EX27367	0000-00-00	1
Drop Test	1	EX27367	0000-00-00	1

1. The Plastic containers are UL Component Recognized.

Test results relate only to the items tested.

Test Record Summary:

The results of this investigation, including construction review and testing, indicate that the products evaluated comply with the applicable requirements in the standard noted below and, therefore, such products are judged eligible to bear UL's Mark as described on the Conclusion Page of this Report.

Standard	Title	Edition or Publication Date	Latest Revision Date
UL 162	UL Standard for Safety for Foam Equipment and Liquid Concentrates	Seventh Edition	2015-06-12

CONCLUSION

Samples of the products covered by this Report have been found to comply with the requirements covering the category and the products are found to comply with UL's applicable requirements. The description and test result in this Report are only applicable to the sample(s) investigated by UL and does not signify UL certification or that the product(s) described are covered under UL's Follow-Up Service Program. When covered under UL's Follow-Up Service Program, the manufacturer is authorized to use the UL Listing Mark on such products which comply with UL's Follow-Up Service Procedure and any other applicable requirements of UL LLC. The Listing Mark of UL LLC on the product, or the UL symbol on the product and the Listing Mark on the smallest unit container in which the product is packaged, is the only method to identify products investigated by UL to published requirements and manufactured under UL's Listing and Follow-Up Service.

This Report is intended solely for the use of UL LLC (UL) and the Applicant for establishment of UL certification coverage of the described product(s) under UL's Follow-Up Service. UL retains all rights, title and interest (including exclusive ownership) in this Report and all copyright therein. The Applicant or its designated agent shall not disclose or otherwise distribute this Report or its contents to any third party, except as required for purposes of compliance with laws, regulations, or other existing agreements or schemes in which UL is currently a participant. Any other use of this Report including, without limitation, evaluation or certification by a party other than UL is prohibited and renders the Report null and void. UL shall not incur any obligation or liability for any loss, expense, or punitive damages, arising out of, or in connection with, the use or reliance upon the contents of this Report to anyone other than the Applicant as provided in the agreement between UL and Applicant. Any use or reference to UL's name or certification mark(s) by anyone other than the Applicant in accordance with the agreement is prohibited without the express written approval of UL. Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. UL shall not otherwise be responsible to anyone for the use of or reliance upon the contents of this Report.

Report by:

Reviewed by:

Jesu Prakash A
Senior Project Engineer

Jerry Kirkpatrick
Lead Engineering Associate

File EX26789
Project 4787742638

February 17, 2017

REPORT

on

Foam Liquid Concentrates

Global Fire Solution Pte Ltd
Singapore

Copyright © 2017 UL LLC

UL LLC authorizes the above named company to reproduce this Report only for purposes as described in the Conclusion, provided it is reproduced in its entirety.

DESCRIPTION

PRODUCT COVERED:

GLOBALCHEM AFFF 3, nominal 3 percent Aqueous Film Forming Foam, +35 F minimum storage and use temperature. Hydrocarbon fuels only.

Foam concentrates for use with the following equipment.

GLOBALCHEM AFFF 3, 3 Percent

PROPORTIONERS - PORTABLE IN-LINE INDUCTORS

ANGUS FIRE LTD, Model UNI225, 2-1/2 in. size, set at 3, inlet pressure of 145 psi with 100 feet of 2-1/2 in. hose between inductor and ANGUS FIRE LTD, Model F225U nozzle.

NOZZLES

Description	Size In.	Inlet Pressure psi
Angus Fire Ltd, Model F225HU	2-1/2	80

PROPORTIONERS - FIXED IN-LINE INDUCTORS

Description	Size, in	Orifice Diam, in	Inlet Pressure, psi	Back Pressure, psi
Angus Fire Ltd, Model IND-40	1-1/2	0.18	135	65

FIXED FOAM DISCHARGE OUTLETS

Description	Orifice Diam, in.	Inlet Pressure, psi
Angus Fire Ltd, Model TPS-50MKV	0.59	60

GENERAL:

CONSTRUCTION DETAILS:

The products have been examined and found to comply with the Standard for Foam Equipment and Liquid Concentrates, UL 162 in effect as of the date of this Report.

USE:

The products covered by this Report are for use in accordance with the National Fire Protection Association Standards for Low Expansion Foam, and/or Foam-Water Sprinklers and Foam-Water Spray Systems, NFPA 11 and 16, respectively.

GENERAL CHARACTER:

Foam liquid concentrates are formulated for addition to water to produce solutions capable of forming fire-fighting foams when the solutions are discharged under pressure through foam making devices.

The foam liquid concentrate covered by this Report is of the Alcohol Resistant Aqueous Film Forming Foam type and is for use in 3 percent solutions for use on hydrocarbon type fuels.

This foam liquid concentrate is suitable for use when the foam temperature is between 35°F (1.7°C) and 120°F (49°C).

TEST RECORD NO. 1

SAMPLES:

Samples of the product as indicated below and constructed as described herein, was submitted by the manufacturer for examination and test.

GLOBALCHEM AFFF 3, nominal 3 percent Aqueous Film Forming Foam, +35 F minimum storage and use temperature. Hydrocarbon fuels only.

Foam concentrate for use with the following equipment.

GLOBALCHEM AFFF 3, 3 Percent

PROPORTIONERS - PORTABLE IN-LINE INDUCTORS

ANGUS FIRE LTD, Model UNI225, 2-1/2 in. size, set at 3, inlet pressure of 145 psi with 100 feet of 2-1/2 in. hose between inductor and ANGUS FIRE LTD, Model F225U nozzle.

NOZZLES

Description	Size In.	Inlet Pressure psi
Angus Fire Ltd, Model F225HU	2-1/2	80

PROPORTIONERS - FIXED IN-LINE INDUCTORS

Description	Size, in	Orifice Diam, in	Inlet Pressure, psi	Back Pressure, psi
Angus Fire Ltd, Model IND-40	1-1/2	0.18	135	65

FIXED FOAM DISCHARGE OUTLETS

Description	Orifice Diam, in.	Inlet Pressure, psi
Angus Fire Ltd, Model TPS-50MKV	0.59	60

GENERAL:

The following tests were conducted:

Test	Paragraph/Clause
Film Forming	6
Foam Quality Tests	8
Class B Fire Tests - Topside Discharge Devices	10
Induction Rate	12
Minimum Storage Temperature	13
Nonmetallic Container Tests - Accelerated Storage	22.3

The following tests were waived:

Test	Rational for Waived Test+	File Reference	Report Date	Test Record No.
Nonmetallic Container Tests - Immersion test for cracking resistance	1	EX27367	0000-00-00	1
Nonmetallic Container Tests - Air-oven aging test	1	EX27367	0000-00-00	1
Nonmetallic Container Tests - Light and water test	1	EX27367	0000-00-00	1
Drop Test	1	EX27367	0000-00-00	1

1. The Plastic containers are UL Component Recognized.

Test results relate only to the items tested.

Test Record Summary:

The results of this investigation, including construction review and testing, indicate that the products evaluated comply with the applicable requirements in the standard noted below and, therefore, such products are judged eligible to bear UL's Mark as described on the Conclusion Page of this Report.

Standard	Title	Edition or Publication Date	Latest Revision Date
UL 162	UL Standard for Safety for Foam Equipment and Liquid Concentrates	Seventh Edition	2015-06-12

CONCLUSION

Samples of the products covered by this Report have been found to comply with the requirements covering the category and the products are found to comply with UL's applicable requirements. The description and test result in this Report are only applicable to the sample(s) investigated by UL and does not signify UL certification or that the product(s) described are covered under UL's Follow-Up Service Program. When covered under UL's Follow-Up Service Program, the manufacturer is authorized to use the UL Listing Mark on such products which comply with UL's Follow-Up Service Procedure and any other applicable requirements of UL LLC. The Listing Mark of UL LLC on the product, or the UL symbol on the product and the Listing Mark on the smallest unit container in which the product is packaged, is the only method to identify products investigated by UL to published requirements and manufactured under UL's Listing and Follow-Up Service.

This Report is intended solely for the use of UL LLC (UL) and the Applicant for establishment of UL certification coverage of the described product(s) under UL's Follow-Up Service. UL retains all rights, title and interest (including exclusive ownership) in this Report and all copyright therein. The Applicant or its designated agent shall not disclose or otherwise distribute this Report or its contents to any third party, except as required for purposes of compliance with laws, regulations, or other existing agreements or schemes in which UL is currently a participant. Any other use of this Report including, without limitation, evaluation or certification by a party other than UL is prohibited and renders the Report null and void. UL shall not incur any obligation or liability for any loss, expense, or punitive damages, arising out of, or in connection with, the use or reliance upon the contents of this Report to anyone other than the Applicant as provided in the agreement between UL and Applicant. Any use or reference to UL's name or certification mark(s) by anyone other than the Applicant in accordance with the agreement is prohibited without the express written approval of UL. Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. UL shall not otherwise be responsible to anyone for the use of or reliance upon the contents of this Report.

Report by:

Reviewed by:

Jesu Prakash A
Senior Project Engineer

Jerry Kirkpatrick
Lead Engineering Associate

File EX26789
Project 4787742638

February 18, 2017

REPORT

on

Foam Liquid Concentrates

Global Fire Solution Pte Ltd
Singapore

Copyright © 2017 UL LLC

UL LLC authorizes the above named company to reproduce this Report only for purposes as described in the Conclusion, provided it is reproduced in its entirety.

DESCRIPTION

PRODUCT COVERED:

GLOBALCHEM AFFF 6, nominal 6 percent Aqueous Film Forming Foam, +35 F minimum storage and use temperature. Hydrocarbon fuels only.

Foam concentrates for use with the following equipment.

GLOBALCHEM AFFF 6, 6 Percent

PROPORTIONERS - PORTABLE IN-LINE INDUCTORS

ANGUS FIRE LTD, Model UNI225, 2-1/2 in. size, set at 6, inlet pressure of 145 psi with 100 feet of 2-1/2 in. hose between inductor and ANGUS FIRE LTD, Model F225U nozzle.

NOZZLES

Description	Size In.	Inlet Pressure psi
Angus Fire Ltd, Model F225HU	2-1/2	80

GENERAL:

CONSTRUCTION DETAILS:

The products have been examined and found to comply with the Standard for Foam Equipment and Liquid Concentrates, UL 162 in effect as of the date of this Report.

USE:

The products covered by this Report are for use in accordance with the National Fire Protection Association Standards for Low Expansion Foam, and/or Foam-Water Sprinklers and Foam-Water Spray Systems, NFPA 11 and 16, respectively.

GENERAL CHARACTER:

Foam liquid concentrates are formulated for addition to water to produce solutions capable of forming fire-fighting foams when the solutions are discharged under pressure through foam making devices.

The foam liquid concentrate covered by this Report is of the Alcohol Resistant Aqueous Film Forming Foam type and is for use in 6 percent solutions for use on hydrocarbon type fuels.

This foam liquid concentrate is suitable for use when the foam temperature is between 35°F (1.7°C) and 120°F (49°C).

TEST RECORD NO. 1

SAMPLES:

Samples of the product as indicated below and constructed as described herein, was submitted by the manufacturer for examination and test.

GLOBALCHEM AFFF 6, nominal 6 percent Aqueous Film Forming Foam, +35 F minimum storage and use temperature. Hydrocarbon fuels only.

Foam concentrates for use with the following equipment.

GLOBALCHEM AFFF 6, 6 Percent

PROPORTIONERS - PORTABLE IN-LINE INDUCTORS

ANGUS FIRE LTD, Model UNI225, 2-1/2 in. size, set at 6, inlet pressure of 145 psi with 100 feet of 2-1/2 in. hose between inductor and ANGUS FIRE LTD, Model F225U nozzle.

NOZZLES

Description	Size In.	Inlet Pressure psi
Angus Fire Ltd, Model F225HU	2-1/2	80

GENERAL:

The following tests were conducted:

Test	Paragraph/Clause
Film Forming	6
Foam Quality Tests	8
Class B Fire Tests - Topside Discharge Devices	10
Induction Rate	12
Minimum Storage Temperature	13

The following tests were waived:

Test	Rational for Waived Test+	File Reference	Report Date	Test Record No.
Nonmetallic Container Tests - Immersion test for cracking resistance	1	EX27367	0000-00-00	1
Nonmetallic Container Tests - Air-oven aging test	1	EX27367	0000-00-00	1
Nonmetallic Container Tests - Light and water test	1	EX27367	0000-00-00	1
Drop Test	1	EX27367	0000-00-00	1
Nonmetallic Container Tests - Accelerated Storage Test	2	EX26789	0000-00-01	1

1. The Plastic containers are UL Component Recognized.
2. Testing on GLOBALCHEM AFFF1 was considered representative for GLOBALCHEM AFFF6

Test results relate only to the items tested.

Test Record Summary:

The results of this investigation, including construction review and testing, indicate that the products evaluated comply with the applicable requirements in the standard noted below and, therefore, such products are judged eligible to bear UL's Mark as described on the Conclusion Page of this Report.

Standard	Title	Edition or Publication Date	Latest Revision Date
UL 162	UL Standard for Safety for Foam Equipment and Liquid Concentrates	Seventh Edition	2015-06-12

CONCLUSION

Samples of the products covered by this Report have been found to comply with the requirements covering the category and the products are found to comply with UL's applicable requirements. The description and test result in this Report are only applicable to the sample(s) investigated by UL and does not signify UL certification or that the product(s) described are covered under UL's Follow-Up Service Program. When covered under UL's Follow-Up Service Program, the manufacturer is authorized to use the UL Listing Mark on such products which comply with UL's Follow-Up Service Procedure and any other applicable requirements of UL LLC. The Listing Mark of UL LLC on the product, or the UL symbol on the product and the Listing Mark on the smallest unit container in which the product is packaged, is the only method to identify products investigated by UL to published requirements and manufactured under UL's Listing and Follow-Up Service.

This Report is intended solely for the use of UL LLC (UL) and the Applicant for establishment of UL certification coverage of the described product(s) under UL's Follow-Up Service. UL retains all rights, title and interest (including exclusive ownership) in this Report and all copyright therein. The Applicant or its designated agent shall not disclose or otherwise distribute this Report or its contents to any third party, except as required for purposes of compliance with laws, regulations, or other existing agreements or schemes in which UL is currently a participant. Any other use of this Report including, without limitation, evaluation or certification by a party other than UL is prohibited and renders the Report null and void. UL shall not incur any obligation or liability for any loss, expense, or punitive damages, arising out of, or in connection with, the use or reliance upon the contents of this Report to anyone other than the Applicant as provided in the agreement between UL and Applicant. Any use or reference to UL's name or certification mark(s) by anyone other than the Applicant in accordance with the agreement is prohibited without the express written approval of UL. Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. UL shall not otherwise be responsible to anyone for the use of or reliance upon the contents of this Report.

Report by:

Reviewed by:

Jesu Prakash A
Senior Project Engineer

Jerry Kirkpatrick
Lead Engineering Associate

File EX26789
Project 4787742638

February 19, 2017

REPORT

on

Foam Liquid Concentrates

Global Fire Solution Pte Ltd
Singapore

Copyright © 2017 UL LLC

UL LLC authorizes the above named company to reproduce this Report only for purposes as described in the Conclusion, provided it is reproduced in its entirety.

DESCRIPTION

PRODUCT COVERED:

GLOBALCHEM AR-AFFF 3/3, nominal 3 percent Alcohol Resistance Aqueous Film Forming Foam, +35 F minimum storage and use temperature. Hydrocarbon Fuels at 3 percent and Polar fuels at 3 percent.

Foam concentrates for use with the following equipment.

GLOBALCHEM AR-AFFF 3/3, 3 Percent

PROPORTIONERS - PORTABLE IN-LINE INDUCTORS

ANGUS FIRE LTD, Model UNI225, 2-1/2 in. size, set at 3, inlet pressure of 145 psi with 100 feet of 2-1/2 in. hose between inductor and ANGUS FIRE LTD, Model F225U nozzle.

NOZZLES

Description	Size In.	Inlet Pressure psi
Angus Fire Ltd, Model F225HU	2-1/2	80

PROPORTIONERS - FIXED IN-LINE INDUCTORS

Description	Size, in	Orifice Diam, in	Inlet Pressure, psi	Back Pressure, psi
Angus Fire Ltd, Model IND-40	1-1/2	0.18	135	65

FIXED FOAM DISCHARGE OUTLETS

Description	Orifice Diam, in.	Inlet Pressure, psi
Angus Fire Ltd, Model TPS-50MKV	0.59	60

Where,

Fuel	Min Application Rate, gpm/ft ²
Alc (Alcohols)	0.16

GENERAL:

CONSTRUCTION DETAILS:

The products have been examined and found to comply with the Standard for Foam Equipment and Liquid Concentrates, UL 162 in effect as of the date of this Report.

USE:

The products covered by this Report are for use in accordance with the National Fire Protection Association Standards for Low Expansion Foam, and/or Foam-Water Sprinklers and Foam-Water Spray Systems, NFPA 11 and 16, respectively.

GENERAL CHARACTER:

Foam liquid concentrates are formulated for addition to water to produce solutions capable of forming fire-fighting foams when the solutions are discharged under pressure through foam making devices.

The foam liquid concentrate covered by this Report is of the Alcohol Resistant Aqueous Film Forming Foam type and is for use in 3 percent solutions for use on hydrocarbon type fuels and 3 percent solutions for use on polar fuels.

This foam liquid concentrate is suitable for use when the foam temperature is between 35°F (1.7°C) and 120°F (49°C).

TEST RECORD NO. 1

SAMPLES:

Samples of the product as indicated below and constructed as described herein, was submitted by the manufacturer for examination and test.

GLOBALCHEM AR-AFFF 3/3, nominal 3 percent Alcohol Resistance Aqueous Film Forming Foam, +35 F minimum storage and use temperature. Hydrocarbon fuels at 3 percent and Polar Fuels at 3 percent.

Foam concentrates for use with the following equipment.

GLOBALCHEM AR-AFFF 3/3, 3 Percent

PROPORTIONERS - PORTABLE IN-LINE INDUCTORS

ANGUS FIRE LTD, Model UNI225, 2-1/2 in. size, set at 3AR, inlet pressure of 145 psi with 100 feet of 2-1/2 in. hose between inductor and ANGUS FIRE LTD, Model F225U nozzle.

NOZZLES

Description	Size In.	Inlet Pressure psi
Angus Fire Ltd, Model F225HU	2-1/2	80

PROPORTIONERS - FIXED IN-LINE INDUCTORS

Description	Size, in	Orifice Diam, in	Inlet Pressure, psi	Back Pressure, psi
Angus Fire Ltd, Model IND-40	1-1/2	0.18	135	65

FIXED FOAM DISCHARGE OUTLETS

Description	Orifice Diam, in.	Inlet Pressure, psi
Angus Fire Ltd, Model TPS-50MKV	0.59	60

GENERAL:

The following tests were conducted:

Test	Paragraph/Clause
Film Forming	6
Foam Quality Tests	8
Class B Fire Tests - Topside Discharge Devices	10
Induction Rate	12
Minimum Storage Temperature	13
Nonmetallic Container Tests - Accelerated Storage	22.3

The following tests were waived:

Test	Rational for Waived Test+	File Reference	Report Date	Test Record No.
Nonmetallic Container Tests - Immersion test for cracking resistance	1	EX27367	0000-00-00	1
Nonmetallic Container Tests - Air-oven aging test	1	EX27367	0000-00-00	1
Nonmetallic Container Tests - Light and water test	1	EX27367	0000-00-00	1
Drop Test	1	EX27367	0000-00-00	1

1. The Plastic containers are UL Component Recognized.

Test results relate only to the items tested.

Test Record Summary:

The results of this investigation, including construction review and testing, indicate that the products evaluated comply with the applicable requirements in the standard noted below and, therefore, such products are judged eligible to bear UL's Mark as described on the Conclusion Page of this Report.

Standard	Title	Edition or Publication Date	Latest Revision Date
UL 162	UL Standard for Safety for Foam Equipment and Liquid Concentrates	Seventh Edition	2015-06-12

CONCLUSION

Samples of the products covered by this Report have been found to comply with the requirements covering the category and the products are found to comply with UL's applicable requirements. The description and test result in this Report are only applicable to the sample(s) investigated by UL and does not signify UL certification or that the product(s) described are covered under UL's Follow-Up Service Program. When covered under UL's Follow-Up Service Program, the manufacturer is authorized to use the UL Listing Mark on such products which comply with UL's Follow-Up Service Procedure and any other applicable requirements of UL LLC. The Listing Mark of UL LLC on the product, or the UL symbol on the product and the Listing Mark on the smallest unit container in which the product is packaged, is the only method to identify products investigated by UL to published requirements and manufactured under UL's Listing and Follow-Up Service.

This Report is intended solely for the use of UL LLC (UL) and the Applicant for establishment of UL certification coverage of the described product(s) under UL's Follow-Up Service. UL retains all rights, title and interest (including exclusive ownership) in this Report and all copyright therein. The Applicant or its designated agent shall not disclose or otherwise distribute this Report or its contents to any third party, except as required for purposes of compliance with laws, regulations, or other existing agreements or schemes in which UL is currently a participant. Any other use of this Report including, without limitation, evaluation or certification by a party other than UL is prohibited and renders the Report null and void. UL shall not incur any obligation or liability for any loss, expense, or punitive damages, arising out of, or in connection with, the use or reliance upon the contents of this Report to anyone other than the Applicant as provided in the agreement between UL and Applicant. Any use or reference to UL's name or certification mark(s) by anyone other than the Applicant in accordance with the agreement is prohibited without the express written approval of UL. Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. UL shall not otherwise be responsible to anyone for the use of or reliance upon the contents of this Report.

Report by:

Reviewed by:

Jesu Prakash A
Senior Project Engineer

Jerry Kirkpatrick
Lead Engineering Associate